

Date : 24 July, 2009

To whom it may concern

Confirmation

Dear Sirs/Madams,

We hereby confirm the face masks's filter of item No. TR-0001, TR-0001C, TR-0001K are supplied by Tianjin TEDA Co. Ltd. whose BFE is up to 99.9% and PFE is up to 99.5%.

For and on behalf of:

FOSHAN NANHAIWONDERFUL NONWOVEN CO.,LTD.



A handwritten signature in black ink, appearing to be "Paul", written over a horizontal line.

Authorized signature

PFE TD-25k
 颗粒过滤效果



Tianjin TEDA Co. Ltd.
 Lab. Number 334705

Latex Particle Challenge
 Page 2 of 2

TABLE 1. Results of Particle Filtration Test
 Sample ID: TD-25K

SAMPLE NUMBER	AVERAGE SAMPLE COUNTS	AVERAGE CONTROL COUNTS	FILTRATION EFFICIENCY
1	69	11696	99.41%
2	70	12626	99.45%
3	58	13592	99.57%
4	57	11574	99.51%
5	39	12270	99.68%

SAMPLE AREA TESTED: 91.5 cm²

PARTICLE SIZE: 0.1 μm (0.102 ± 0.003 μm)

PARTICLE BACKGROUND: <1 particles/min

AVERAGE FILTRATION EFFICIENCY: 99.52%

STANDARD DEVIATION: 0.108



PFE TD-25K
700 (0.110)
100 067



Prepared For:
Jinyu Li
Tianjin TEDA Co. Ltd.
South Yinhe Road, Beichen District
Tianjin City, 300400
P.R. China

Submitted By
Nelson Laboratories, Inc.
6280 South Redwood Road
Salt Lake City, UT 84123 6600
801-963 2600
Page 1 of 2

LATEX PARTICLE CHALLENGE - FINAL REPORT

Laboratory Number:	334705
Procedure Number:	SOP/ARO/D11K.1
Sample Source:	Tianjin TEDA Co. Ltd.
Sample Identification:	Refer to Table 1
Deviations:	None
Data Archive Location:	Sequentially by lab number
Statement of Uncertainty:	If applicable, available upon request
Sample Received Date:	19 Jun 2006
Lab Phase Start Date:	14 Jul 2006
Lab Phase Completion Date:	17 Jul 2006
Report Issue Date:	18 Jul 2006

The Latex Particle Challenge procedure is performed to determine the particle filtration efficiency of various materials and filtration devices using a challenge of monodispersed polystyrene (latex) microspheres obtained from Duke Scientific, Palo Alto, CA.

The procedure employed the basic test method described in ASTM F2299, but incorporates a non-neutralized challenge. In real use, particles carry a charge, thus this challenge represents a more natural state. The non-neutralized aerosol is also specified in the FDA guidance document on surgical face masks. The flow rate through the test system was maintained at 1 CFM \pm 5%. The control particle concentration passed through the sample was maintained at 10,000-15,000 particles per cubic foot. Filtration efficiencies are calculated by comparison to control values.

RESULTS:

A reference control was included to verify the test system was within acceptable control limits. The results are summarized in Table 1.

Karl Perkes
Karl Perkes, B.S. RM(NRM)
Study Director

19 Jul 2006
Study Completion Date

bav



All systems are tested under the supervision of Nelson Laboratories, Inc. for the exclusive use of the equipment to which they are addressed. Reports may not be reproduced, copied, or otherwise used. No guarantee is made as to the accuracy of the data or the results of the tests performed. The significance of any data is subject to the adequacy and representativeness thereof of the samples tested. Nelson Laboratories, Inc. warrants that all tests are performed in accordance with established laboratory procedures and standards. Nelson Laboratories, Inc. makes no other warranties or any other express or implied. Nelson Laboratories, Inc. expressly disclaims any liability for warranty regarding the adequacy of the samples tested for testing for any specific use of application, that determination being the sole responsibility of the sponsor. Nelson Laboratories, Inc. is not liable for any loss or damage resulting from its actions or failure to act that will exceed the cost of tests performed and it shall not be liable for any material or consequential damage.

BFE TDR - 22

NELSON LABORATORIES

Prepared For
Jinyu Li
Tianjin TEDA Co. Ltd.
South Yinhe Rd., Beichen Dist.
Tianjin City 300400
P.R. CHINA

Submitted By:
Nelson Laboratories, Inc.
0280 South Redwood Road
Salt Lake City, UT 84123-6600
801-963-2600
Page 1 of 2

BACTERIAL FILTRATION EFFICIENCY AND DIFFERENTIAL PRESSURE – FINAL REPORT

Laboratory Number:	359508
Procedure Number:	SOP/ARO/007L.1
Sample Source:	Tianjin TEDA Co. Ltd.
Sample Identification:	Refer to Table 1
Deviations:	None
Statement of Uncertainty:	If applicable, available upon request
Andersen Sampler Flow Rate:	28.3 L/min. (1 CFM)
BFE Conditioning:	4 hours minimum at 21 ± 5°C and 85 ± 5% relative humidity
Sample Received Date:	15 Jan 2007
Lab Phase Start Date:	16 Jan 2007
Lab Phase Completion Date:	13 Feb 2007
Report Issue Date:	14 Feb 2007
Results:	Refer to Table 1

The Bacterial Filtration Efficiency (BFE) procedure is performed to determine the filtration efficiency of various materials and filtration devices using a challenge organism of *Staphylococcus aureus*. This procedure complies with ASTM F2101. The Differential Pressure (Delta P or ΔP) test is performed to determine the air exchange differential (breathability) of porous materials.

C-DH
Technical Reviewer

Stacey Cushing
Stacey Cushing, B.S.
Study Director

15 Feb 2007
Study Completion Date

bav



All results and reports issued by Nelson Laboratories, Inc. are for the exclusive use of the sponsor to whom they are addressed. Reports may not be reproduced, copied, or their contents quoted from records or use of the same in any way is permitted except as expressly authorized by Nelson Laboratories, Inc. in writing. The significance of any data is subject to the accuracy and representative character of the methods employed for testing. Nelson Laboratories, Inc. warrants that all tests are performed in accordance with established laboratory procedure and standards. Nelson Laboratories, Inc. makes no other warranties of any kind, express or implied. Nelson Laboratories, Inc. expressly states that it makes no representation or warranty regarding the accuracy of the services rendered for testing for any specific use of apparatus that determination being the sole responsibility of the sponsor. Nelson Laboratories liability for any loss or damage resulting from its actions or failure to act shall not exceed the cost of tests performed, and it shall not be liable for any incident or consequential damages.

BFE TDK-22
细菌过滤效果



Tianjin TEDA Co. Ltd.
Lab Number 359508

Bacterial Filtration Efficiency
and Differential Pressure
Page 2 of 2

TABLE 1. Results

SAMPLE IDENTIFICATION	ΔP (mm H ₂ O/cm ²)	PERCENT BFE
TDK-22 - 1	1.7	99.9%
TDK-22 - 2	1.5	99.8%
TDK-22 - 3	1.4	>99.9%
TDK-22 - 4	1.3	99.8%
TDK-22 - 5	1.2	99.9%

CONTROL AVERAGE: 2653 CFU

MEAN PARTICLE SIZE (MPS): 2.8 μm

